

FLOW RATE

44SPOUT 83SPOUT

Data 05/11/2019

N°	p hot/cold [bar]	l/min
1	0.1	4.5
2	0.2	6.4
3	0.3	7.8
4	0.4	9
5	0.5	10.1
6	1	14.2
7	1.5	17.5
8	2	20.4
9	2.5	22.7
10	3	25.0
11	3.5	26.9
12	4	29.1
13	4.5	31.2
14	5	33.1

Condizioni di prova

T hot water 63 °C ±3°

T cold water 10÷15°C

MIX temp. 38°C

- 1 = HAND SHOWER SIDE*
- 2 = SPOUT

(*W/OUT HAND SHOWER)

